

PART 2: DESIGN DATA

If using assumed elevations, note this in Additional Information.



1. Force main length:	<u>207</u> ft.	(actual length along proposed alignment)			
Force main diameter (inside):	<u>6.08</u> in.	inside dia.			
Force main material (i.e., PVC C-900 class 150, ductile iron class 52, HDPE DR17 class 100, etc.):	<u>C900 PVC CL150</u>				
Force Main is:	<input checked="" type="checkbox"/>	<u>New</u>	<u>Existing</u>		
2. Elevation change from lift station site to force main discharge point:	<u>-9.4</u> ft.				
Finish grade elevation at wet well:	<u>707.83</u> ft.				
Discharge piping elevation at valve vault:	<u>703.75</u> ft.				
Force main discharge elevation:	<u>698.4</u> ft.				
3. Influent sewer elevation:	<u>697.22</u> ft.				
4. Peak design flow (maximum flow to lift station):	<u>180</u> g.p.m.				
5. Standby generator requirement:	<input checked="" type="checkbox"/> None	<u>Permanent</u>	<u>Portable</u>	<u>None</u>	<u>Don't Know</u>
Standby generator fuel:	SELECT ONE	<u>Diesel</u>	<u>Natural Gas</u>	<u>Propane</u>	
6. Available power supply:	<input checked="" type="checkbox"/> 480V	<u>208V</u>	<u>240V</u>	<u>480V</u>	
	<input checked="" type="checkbox"/> 3-phase	<u>Single-phase</u>	<u>3-phase</u>		
Additional loads on site (besides the lift station) to be powered by generator:	<u> </u>	KVA			
7. Electrical controls weather protection:	SELECT ONE	<u>Enclosed Building</u>	<u>Shelter Structure</u>	<u>None</u>	
Weather protection structure is for:	SELECT ONE	<u>Electrical Controls Only</u>			
		<u>Electrical Controls & Generator</u>			
		<u>Controls, Generator, Chemical Feed</u>			