PART 2: DESIGN DATA

If using assumed elevations, note this in Additional Information.



1. Force main length: ? ft. (actual length along proposed alignment)

Force main diameter (inside): ? in. inside dia.

Force main material (i.e., PVC C-900 class 150, ductile iron class 52, HDPE DR17 class 100, etc.): ?

Force Main is: [ ] New Existing

2. Elevation change from lift station site to force main discharge point: 16 ft.

Finish grade elevation at wet well: 100 ft.

Discharge piping elevation at valve vault: 96 ft.

Force main discharge elevation: 116 ft.

3. Influent sewer elevation: 95 ft.

4. Peak design flow (maximum flow to lift station): 540 gpm @280' TDH- 2 pumps running

5. Standby generator requirement: [None] Permanent Portable None Don't Know

Standby generator fuel: [ ] Diesel Natural Gas Propane

6. Available power supply: [480V] 208V 240V 480V

[3-phase] Single-phase 3-phase

Additional loads on site (besides the lift station) to be powered by generator: ____ KVA

7. Electrical controls weather protection: [None] Enclosed Building Shelter Structure None

Weather protection structure is for: [SELECT ONE] Electrical Controls Only

Electrical Controls & Generator

Controls, Generator, Chemical Feed