



- NOTES:
1. LIGHT SWITCH ASSEMBLY INSTALLED.
  2. SCE-DSTOPK POSITIONED FOR 135 DEGREE STOP.
  3. ATTACH COPY OF SCHEMATIC TO INSIDE OF DOOR.
  4. ATTACH SEALING RING FOR BEACON ON INSIDE OF ENCLOSURE.



NO.	DATE	DESCRIPTION	BY
1	1-18-06	SUBMITTAL DRAWING	AD
			AD

UL LISTED LIFT STATION CONTROL PANEL & PUMP DISCONNECT  
 PANEL-DUPLEX PUMPS

**ROMTEC UTILITIES**  
 18240 NORTH BANK ROAD  
 ROSEBURG, OR 97470  
 (541)-496-3541  
 FAX (541)-496-0803  
 WWW.romtecutilities.com

CITY OF BRAWLEY  
 AMMONIA REMOVAL  
 CONTROL PANEL LAYOUT  
 ELECTRICAL CONTROLS  
 DUPLEX LIFT STATION SYSTEM

SHEET  
 1 OF 2  
 JOB NUMBER