10.00

36.00

60.00

DOOR SWITCH
DS1

MAIN
DISCONNECT

PUMP 1
RUN

PUMP 2
RUN

PUMP 1
H O A

PUMP 2
H O A

PUMP 1
AL SEAL

PUMP 2
AL SEAL

PUMP 1
THERMAL/SEAL

PUMP 2
THERMAL/SEAL

PUMP 1
DISCONNECT

PUMP 2
DISCONNECT

GENERATOR
20 15A

AUTO
20 5A

GFCI
RECEPTACLE

AL1

AL1

LEFT SIDE VIEW

FRONT VIEW

FLOOR KIT
HOFFMAN
AFK1212
PAINTED STEEL

PUMP CONTROL PANEL

60"H x 36"W x 10"D

FRONT VIEW WITH OUTER DOORS REMOVED

NOT SHOWN 3 POINT LOCKABLE LATCH

ALL PANELS ARE UL 698 LISTED FOR INTRINSICALLY SAFE CIRCUITS

THE ENCLOSURE SHOWN REPRESENTS THE INTENT OF THE DESIGN. OFTEN THE
ENCLOSURE SIZE AND LAYOUT MUST CHANGE TO ACCOMMODATE THE REQUIRED
COMPONENTS AND FINAL DESIGN. PLEASE CONTACT ROMTEC UTILITIES TO OBTAIN
ACTUAL AS-BUILT DRAWINGS BEFORE INSTALLATION.

DWG. -

DSN. KAS
DRN. KAS
CKD. KAS

REV DATE
1   11/1/12

E0104D01

BY

DESCRIPTION
REVISIONS

THE MARKE

DUPLEX
CONTROL PANEL LAYOUT
MICROLOGIXS DUPLEX CONTROL

SHEET
1 OF 1

JOB NUMBER