

5.02 LIFT STATION DESIGN CRITERIA




Romtec Utilities has designed this Scope of Supply and Design Submittal based on the following information:

PART 1: PROJECT CONTACT INFORMATION

Date:	9/14/2015		
Project Name:	Tulare Lift Station		
Information here in provided by:	City of Shafter		
Name:	_____		
Email Address:	_____		
Telephone:	_____	Phone Ext:	_____
Project Site Address:	Shafter, CA		
ACAD site plan drawing available at this time?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Final Project Owner and/or Operator:	City of Shafter		
Governing Sewer or Water Authority:	City of Shafter		
Does Authority have a lift station standard?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does this project require "Buy America" materials?	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	<input type="checkbox"/> No

PART 2: DESIGN DATA

Note: The drawing below is purely to represent elevations. It does not reflect the design of the lift station.



Source of Water:	Existing development		
Water Type:	Wastewater		
Peak design inflow (max flow to lift station):	350 g.p.m.		
Pumping Rate:	350 g.p.m.		
1. Influent sewer elevation:	338.08 ft.		
2. Finish grade elevation at wet well:	348.3 ft.		
3. Force main length:	286 ft.		
4. Force main discharge elevation:	343.59 ft.		
Force main diameter:	6 in. inside dia.		
Force main material (PVC, DI, etc.):	PVC C900 DR25		
Force Main is:	<input checked="" type="checkbox"/> New	<input type="checkbox"/> New	<input type="checkbox"/> Existing
Force Main Discharge (manhole, pressure force main, etc.)	Manhole		
Standby generator (BY OTHERS):	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Permanent	<input type="checkbox"/> Portable
Generator fuel:		<input type="checkbox"/> Diesel	<input type="checkbox"/> Natural Gas
Power Supply:	<input checked="" type="checkbox"/> 240V	<input type="checkbox"/> 480V	<input type="checkbox"/> 240V
Power Supply:	<input checked="" type="checkbox"/> Three-Phase	<input type="checkbox"/> Three-Phase	<input type="checkbox"/> Single-phase
Is lift station a classified space?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> Yes	<input type="checkbox"/> No