



- GENERAL NOTES**
1. ALL UASB TANKS, TANK PADS, AND TANK PIPE CONNECTION ARE OWNER FURNISHED.
 2. ALL GLDI PIPE SHALL HAVE RESTRAINED JOINTS, EXCEPT WHERE IDENTIFIED AS FLANGED.
 3. PIPES SHALL HAVE A MINIMUM OF 3-FEET OF COVER, UNLESS OTHERWISE SHOWN.
 4. ALL PIPES SHALL HAVE A CONSTANT SLOPE BETWEEN INVERT ELEVATIONS UNLESS A FITTING IS SHOWN.
 5. CONTRACTOR SHALL MAINTAIN A MINIMUM 18-INCH VERTICAL SEPARATION BETWEEN THE BOTTOM OF THE POTABLE WATER LINE (W1) AND THE CROWN OF THE NON-POTABLE LINE.
 6. ARROWS SHOW PROCESS FLOW DIRECTION.



ORIGINAL DRAWING SIGNED AND DATED ON 07/27/2012 BY REGISTRANT SHOWN. ORIGINAL DRAWING IS STORED AT CH2M HILL ESCO DAKO

NO.	DATE	DESIGN	DR	BY	APP'D
2	7/31/12	ADDENDUM 2	AR	JB	JB
1	6/26/12	ADDENDUM 1	AR	JB	JB
		DESIGN	DR	BY	APP'D
			J. BURMAN	A. COLLINS	B. ROBERTS
				CHK	S. MORANDON

CHOBANI INDUSTRIAL WASTEWATER
PRETREATMENT FACILITY
FOR THE CITY OF TWIN FALLS
TWIN FALLS, IDAHO

CH2MHILL®
CIVIL
**ENLARGED YARD PIPING PLAN
AREA B**

VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

DATE	JUNE 8, 2012
PROJ	429376
DWG	C203
SHEET	27 of 102