



STARBUCKS 620
SITE LAYOUT
12/12/18
BASED ON CUSTOMER
SITE PLAN DWG RECEIVED ON
12/10/18

WET WELL DEPTH=13'
PUMP CABLE LENGTH=20ft
LEVEL SENSING CABLE LENGTH=65ft
JUNCTION BOX FOR PUMP CABLE
CONNECTION IS NOT SUPPLIED BY ROMTEC
UTILITIES. THIS MUST BE SUPPLIED BY
THE SITE ELECTRICAL CONTRACTOR.

ROMTEC UTILITIES
18240 NORTH BANK RD.
ROSEBURG, OR 97470 (541) 496-9678
© 2019 ROMTEC INC. ALL RIGHTS RESERVED. THESE
PLANS AND DRAWINGS MAY NOT BE REPRODUCED,
ADAPTED, OR FURTHER DISTRIBUTED, AND NO
COMPONENTS MAY BE CONSTRUCTED FROM THESE
PLANS, WITHOUT WRITTEN PERMISSION OF ROMTEC, INC.

STARBUCKS 620
SAN CLEMENTE, CA
WET WELL ASSEMBLY
COMPONENT DRAWING

MECHANICAL SHEET
3 OF 4

VERIFY SCALE
DRAWING SCALE
1" = 10'-0"
FIELD SCALE
1" = 10'-0"
SCALE ACCURACY
± 0.1'

DATE: 12-5-18

18240 NORTH BANK ROAD
ROSEBURG, OREGON 97470
PHONE: (541) 496-9678
WWW.ROMTECUTILITIES.COM

REV	DATE	DESCRIPTION	BY
1			