

## 1.02 DESIGN CRITERIA

Romtec Utilities has created this SSDS based solely on the design criteria listed below that the customer and/or customer's representative has provided. It is the responsibility of the customer as well as any other reviewing entities, to verify that the stated design criteria is accurate. Romtec Utilities has not verified the design criteria and does not have responsibility for confirming its accuracy.

<b>Project Name:</b>	City of Hesperia Booster Station
<b>Design information provided by:</b>	Merrell-Johnson Engineering
<b>Source of Water:</b>	Above Grade Reservoir
<b>Water Type:</b>	Irrigation Water
<b>Final Owner/Operator:</b>	City of Hesperia
<b>CAD site plan available at this time?</b>	Yes
<b>Does this project require "Buy America" materials?</b>	No
<b>Inlet Size (In.)</b>	8
<b>Force Main is (new/existing):</b>	New
<b>Force main length (ft.):</b>	53,000
<b>Force main inside diameter (in.):</b>	10
<b>Force main pipe material:</b>	PVC
<b>Peak design inflow into station (g.p.m):</b>	700
<b>System Total Dynamic Head (ft.):</b>	150 (feed head of 20')
<b>Pumping Rate (g.p.m):</b>	700
<b>Power Supply Voltage:</b>	480V
<b>Power Supply Phase:</b>	Three-Phase
<b>Is the lift station a classified space thus requiring the pumps to be explosion proof?</b>	No