


INNER DOORS



BACK PLATE

BACK PLATE/INNER DOOR LAYOUT

THIS DRAWING CONTAINS PROPRIETARY INFORMATION WHICH MUST NOT BE DUPLICATED, USED, OR DISCLOSED IN WHOLE OR IN PART WITHOUT PRIOR WRITTEN CONSENT.

SHEET NUMBER  
9 OF 10

NO.	REVISION HISTORY	DATE	BY
1.0	SUBMITTAL	3/21/19	WH



18240 NORTH BANK ROAD  
ROSEBURG, OREGON 97470  
PHONE: (541) 496-9678  
WWW.ROMTECUTILITIES.COM

ROMTEC UTILITIES  
BEDFORD, NOVA SCOTIA  
SHIPYARD ROAD PUMP STATION  
QUOTE: 20181837

DRAWN BY: WH  
DATE: 3/21/19

PANEL REQUIREMENTS  
SYM.  
VOLTAGE 208/120 VAC  
PHASE 3 PHASE 4 WIRE  
FREQUENCY 60 Hz  
SCCR 5 KA RMS SYM  
TOTAL FLA 62.8 FLA  
TYPE 4X

LARGEST MOTOR POWER REQUIREMENTS  
HP 7.2 HP  
FLA 19 FLA

PROJECT NUMBER  
7004888A