



REVISION NOTES:

1. RELOCATE PANEL HEATER "HTR1" TO ALLOW FOR A MINIMUM OF 1" CLEARANCE FROM THE PANEL HEATER TO THE MAIN BREAKER.
2. RELOCATE THE BATTERY CHARGER POWER SUPPLY "PS1" TO ALLOW 1-1/2" CLEARANCE BETWEEN THE POWER SUPPLY AND THE HEATER WHILE MAINTAINING A 1/2" CLEARANCE BETWEEN THE POWER SUPPLY AND WIRING DUCT.

NO.	DATE	DESCRIPTION	BY
2	11/8/16	RELOCATED PS1 AND HTR1	KAS
1	8/4/16	ADDED PURGE SYSTEM	KAS
			REVISIONS

cULus LISTED AS ENCLOSED INDUSTRIAL CONTROL PANEL FOR USE IN HAZARDOUS (CLASSIFIED) LOCATION CLASS I, DIVISION 2, GROUPS C & D

ROMTEC UTILITIES
 18240 NORTH BANK ROAD
 ROSEBURG, OR 97470
 (541)-496-9678
 FAX (541)-496-0804
 WWW.romtecutilities.com

SHEET
 3 OF 3