

## 5.02 LIFT STATION DESIGN CRITERIA FORM

Romtec Utilities has designed this Scope of Supply and Design Submittal based on the following information:

Design Criteria  
Date: 5/23/2014


### PART 1: PROJECT CONTACT INFORMATION

Information here in provided by:	<u>Mark Thomas and Company</u>				
Company/Agency Type:	<u>Engineer</u>	<u>Engineer</u>	<u>Developer</u>	<u>Gov't. Agency</u>	<u>Other</u>
First Name:	_____				
Last Name:	_____				
Title:	_____				
Email Address:	_____				
Address:	_____				
City:	<u>Antioch</u>				
State/Province:	<u>California</u>	Zip Code:	_____		
Country:	<u>USA</u>				
Telephone:	_____		Phone Ext:	_____	
Mobile/Other Phone:	_____		Fax:	_____	
Project Name:	<u>Antioch Gypsum Plant</u>				
Your Client for this project is:	<u>Private Co.</u>	<u>Public Agency</u>	<u>Private Co.</u>		
Project Type:	<u>Stormwater</u>	<u>Wastewater</u>	<u>Stormwater</u>	<u>Other</u>	
Project City:	<u>Antioch</u>	Project Zip:	_____		
Project Engineer:	<u>Chris Briana</u>				
Reviewing Entity who reviews/approves this Scope of Supply & Design Submittal:	<u>N/A</u>				
Final Project Owner and/or Operator:	<u>N/A</u>				
Governing Sewer or Water Authority:	<u>N/A</u>				
Does Authority have a lift station standard?	<u>N/A</u>	<u>Yes</u>	<u>No</u>	<u>N/A</u>	
Who should Romtec contact about the lift station design standard?	<u>N/A</u>				
What is the Expected Project Bid Date?	<u>N/A</u>	Project Completion Date:	_____		

## 5.02 LIFT STATION DESIGN CRITERIA FORM

### PART 2: DESIGN DATA

If using assumed elevations, note this in Additional Information.



1. Force main length: 200 ft. (actual length along proposed alignment)

Force main diameter (inside): 14 in. inside dia.

Force main material (i.e., PVC C-900 class 150, ductile iron class 52, HDPE DR17 class 100, etc.): PVC C905 DR25

Force Main is:  New       New       Existing

Source of Water: Storm runoff collection from plant facilities.

2. Elevation change from lift station site to force main discharge point: 1 ft.

Finish grade elevation at wet well: 25 ft.

Discharge piping elevation: 21 ft.

Force main discharge elevation: 26 ft.

3. Influent sewer elevation: 12 ft.

4. Peak design inflow (maximum flow to lift station): 3100 g.p.m.

5. Is this lift station considered a classified space?  No       Yes       No

6. Standby generator requirement:  Portable       Permanent       Portable       None       Don't Know

Standby generator fuel:  Diesel       Natural Gas       Propane

7. Available power supply:  480V       208V       240V       480V

3-phase       Single-phase       3-phase

Additional loads on site (besides the lift station) to be powered by generator: \_\_\_\_\_ KVA