1.04 **DESIGN CRITERIA FORM**



Romtec Utilities has designed this Scope of Supply and Design Submittal based on the following information provided by:

Date:

Project Name:

Information here in provided by:

9/6/2018

Glenwood and Laurin Pump Station

Olson Engineering

DESIGN CRITERIA

Project Site Address:

CAD site plan available at this time?

Final Project Owner and/or Operator:

Governing Sewer or Water Authority:

Does Authority have a lift station standard? Does this project require "Buy America"

materials?


Source of Water: Water Type:

Vancouver, Washington

Yes	<u>Yes</u>	<u>No</u>	<u>N/A</u>	
CRWWD				
Yes	<u>Yes</u>	<u>No</u>	N/A	
No	Yes	No	N/A	

Wastewater

Wastewater



Peak design inflow (max flow to lift station): 80 gpm

Pumping Rate: 127 gpm (Greater than peak design inflow)

New

1. Influent sewer elevation: 279.56 ft.

2. Finish grade elevation at wet well: 289.75 ft.

3. Force main length: 9756 ft.

4. Force main discharge elevation: 193.09 ft.

Force main diameter: 4 in. inside dia.

Force main material (PVC, DI, etc.): PVC C900 DR18

Force Main Discharge (manhole, pressure force m

Standby generator:

Generator fuel:

Force Main is:

Power Supply:

Power Supply:

Is the lift station a classified space?

N/A <u>I</u>	<u>Permanent</u>	<u>Portable</u>

Diesel

New

Existing

Natural Gas

N/A

208V

480V 480V 240V Three-Phase Three-Phase Single-phase

> Yes Yes No