


## 5.02 LIFT STATION DESIGN CRITERIA FORM

### PART 2: DESIGN DATA



1. Force main length: 510 ft. (actual length along proposed alignment)

Force main diameter (inside): 4 in. inside dia.

Force main material (i.e., PVC C-900 class 150, ductile iron class 52, HDPE DR17 class 100, etc.):

HDPE DR-7

Force Main is:

☒ New

☐ New

☐ Existing

Force Main Discharge (i.e., manhole to gravity sewer, pressure force main, storage tank, etc.):

Gravity manhole

Source of Water:

Main pumping station building

2.a Elevation change from lift station site to force main discharge point: 5 ft.

2.b Finish grade elevation at wet well: 185 ft.

2.c Discharge piping elevation at lift station: 182 ft.

2.d Force main discharge elevation: 190 ft.

3.a Influent sewer depth: 5 ft.

3.b Influent sewer elevation: 180 ft.

4. Peak design inflow (maximum flow to lift station): 30 g.p.m. @ 30 ft TDH

Pumping Rate: 30 g.p.m.

5. Standby generator requirement: ☒ None ☐ Permanent ☐ Portable ☐ None ☐ Don't Know

Standby generator fuel:

☐ Diesel

☐ Natural Gas

☐ Propane

6. Available power supply: ☒ 480V ☐ 208V ☐ 240V ☐ 480V

☒ 3-phase

☐ Single-phase

☐ 3-phase

Is this lift station considered a classified space?

☒ No

☐ Yes

☐ No