

1. Force main length:

Force main diameter (inside):

Force main material (i.e., PVC C-900 class 150, ductile iron class 52, HDPE DR17 class 100, etc.):

Force Main is:

Elevation change from lift station site to force main discharge point:

Finish grade elevation at wet well:

Discharge piping elevation at valve vault:

Force main discharge elevation:

- 3. Influent sewer elevation:
- Peak design flow (maximum flow to lift station):
- **5.** Standby generator requirement:

Standby generator fuel:

Available power supply:

Additional loads on site (besides the lift station) to be powered by generator:

7. Electrical controls weather protection:

Weather protection structure is for:

248 ft. (actual length along proposed alignment) 4 in. inside dia.

N/A

C.I.				
Existing	<u>New</u>	Existing		
31.3	ft.			
169.5	ft.			
165.5	ft.			
200.75	ft.			
157.1	ft.			
<u>8</u> g.p.m.				
Permanent	<u>Permanent</u>	<u>Portable</u>	<u>None</u>	Don't Know
Diesel	<u>Diesel</u>	Natural Gas	<u>Propane</u>	
240V	<u>208V</u>	<u>240V</u>	<u>480V</u>	
3-phase	<u>Single-phase</u>	3-phase		

Shelter Structur **None** Building **Structure Electrical Controls Only** Electrical Controls Only

Enclosed

KVA

Electrical Controls & Generator

Shelter

Controls, Generator, Chemical Feed