



NOTE:
GENERATOR SHALL BE 50KVA, DIESEL-POWERED, WITH SUB-BASE FUEL TANK (24 HOUR CAPACITY) AND WEATHER ENCLOSURE.



PRELIMINARY



LACO ASSOCIATES
CONSULTING ENGINEERS

21 W 4TH ST. EUREKA, CA 95501 (707)443-5054

NO.	REVISION	BY	CHK	DATE

**NORTHCREST DRIVE
SEWER EXTENSION
LIFT STATION SITE PLAN**

**COUNTY OF DEL NORTE
CRESCENT CITY, CALIFORNIA**

SCALE	AS SHOWN
DRAWN	JDB
CHECK	CJR
APPVD	CJR
DATE	10/28/10
JOB NO.	7337.00
SHEET	C4

Oct 28 2010 1:26pm T:\CoFiles\300\7337 DEL NORTE SEWER - NORTHCREST DR\dwg\ 7337 CIV C4.dwg