PROJECT INFO PACKAGE/STARTUP Job Name: Palomino Ranch Offering: Complete System Mechanical: All by Romtec Utilities Company: DEA Contact: Pumps: By Romtec Utilities Job Type: **New Station** Control Panel: By Romtec Utilities Water Type/Source: Stormwater Generator N/A Advisor/Startup: Mechanical & Electrical Import/Domestic: Import Acceptable Turnkey: No DESIGN CRITERIA - SWC10D-00-D0200-2000x20-10D-43-0 FLOW RATE 2000 GPM 582.80 Peak Inflow: RIM: Pumping Rate: GPM (of single pump) 2000 Static Head: 19.2 Feet FINISH GRADE: 582.80 TDH: 16.3 Feet **RU Calcs** TDH Calcs: **ACTIVE VOLUME** Max Pump Starts: 10.00 Starts/Hr 578.00 Cycle Time: 6.00 Minutes DISCHARGE C.L 3000.00 Active Volume: Gallons Active Volume: 401.06 Cu Feet Well Shape: Round Well Diameter: 10 Well Dimensions: N/A N/A Cross-Section Area: 78.54 Sq Feet Min. Depth Required: 0.37 Feet Active Depth: 0.40 Feet STORAGE VOLUME (if required) Minutes 568.24 Time: INVERT: HIGH LEVEL: Flow Rate: GPM 576.50 LAG START: Volume: 0.00 Gallons 570.20 Volume: 0.00 Cu. Feet LEAD START: 570.20 Min. Depth Required: 0.00 Feet Storage Depth: Feet PUMP STOP: 569.80 ∇ ON-SITE POWER 480V / 3-Phase Power: FORCE MAIN FM Info: SUMP: 566.80 New Single FM Length: 30 Feet FM Discharge: 589.00 Feet BASE: 565.63 FM High Point: 589.00 Feet Note: Image is a preliminary representation of the pumping system. (2) (3)(1) Nominal ID: 12" Elevations shown are the primary factors used for sizing the wet well.

General Specification

Influent Invert:

Influent Size: Type:

INFLUENT PIPING

Type/Rating:

A. The package pump station supplier of the sewer lift station shall be Romtec Utilities. The package pump station supplier shall design and draw the complete lift station including the wet well structure and associated piping and valves along with the control panel and the associated schematics.

Backup levels not shown. Additional (or fewer) level settings may be required.

- B. The package pump station supplier shall be solely responsible for proper prefabrication, integration, supply, performance, and warranty of all package pump station components delineated in this specification and on the drawings, which shall be used as a guide of the minimum product specifications that shall be met.
- C. The package pump station supplier work shall include designing and supplying the piping, mechanical, and appurtenances within and adjacent to the wet well as a complete, predesigned, packaged pump station as described herein.

(3)

- D. The drawings shall be of sufficient detail for the Engineer to review for conformity to the contract. All drawings shall include elevations on the same datum point as in the contract plans.
- E. Romtec Utilities will manufacture and deliver the pump station as described below to the job site for the contractor. A representative of Romtec Utilities will be present the day of the
- F. The package pump station supplier is responsible for overseeing all start-up, testing and training procedures.

ASSUMED PVC C905 DR18

(1)

568.24