PROJECT INFO PACKAGE/STARTUP NORTON LANDING Job Name: Offering: **Complete System** Mechanical: Company: Contact: Pumps: Job Type: **New Station** Control Panel: Water Type/Source: Wastewater (Sewage) Generator: Import/Domestic: Import Acceptable Advisor/Startup: Turnkey: No **DESIGN CRITERIA - WWC5D-V0-D0020-60x20-2P-21-00G** FLOW RATE Peak Inflow: 50 GPM RIM: 160.33 GPM (of single pump) **Pumping Rate:** 62.2 Static Head: 10.4 Feet FINISH GRADE: 160.33 TDH: 22.0 Feet TDH Calcs: **RU Calcs ACTIVE VOLUME** Max Pump Starts: 10.00 Starts/Hr Cycle Time: 6.00 Minutes DISCHARGE C.L. 156.83 Active Volume: 93.30 Gallons Active Volume: 12.47 Cu Feet Well Shape: Round Well Diameter: 5 Well Dimensions: N/A N/A Cross-Section Area: 19.63 Sq Feet Min. Depth Required: 0.64 Feet Active Depth: 0.70 Feet STORAGE VOLUME (if required) Minutes 149.19 Time INVERT: HIGH LEVEL: Flow Rate: GPM 147.93 LAG START: Volume: 0.00 Gallons 147.43 Volume: 0.00 Cu. Feet LEAD START: Min. Depth Required: 0.00 Feet 146.93 Storage Depth: Feet PUMP STOP 146.23 ∇ **ON-SITE POWER** 240V / 1-Phase Power: FORCE MAIN FM Info: 143.73 New Single FM SUMP: Length: 86 Feet FM Discharge: 156.58 Feet BASE: 142.73 FM High Point: 156.58 Feet Note: Image is a preliminary representation of the pumping system. (2) (3) (1)Nominal ID: Elevations shown are the primary factors used for sizing the wet well. HDPE DR17 (assumed) Type/Rating: Backup levels not shown. Additional (or fewer) level settings may be required. INFLUENT PIPING (1)(3)

General Specification

Influent Invert:

Influent Size:

Type:

149.19

ጸ"

PVC (DIPS)

- A. The package pump station supplier of the sewer lift station shall be Romtec Utilities. The package pump station supplier shall design and draw the complete lift station including the wet well structure and associated piping and valves along with the control panel and the associated schematics.
- B. The package pump station supplier shall be solely responsible for proper prefabrication, integration, supply, performance, and warranty of all package pump station components delineated in this specification and on the drawings, which shall be used as a guide of the minimum product specifications that shall be met.
- C. The package pump station supplier work shall include designing and supplying the piping, mechanical, and appurtenances within and adjacent to the wet well as a complete, predesigned, packaged pump station as described herein.

155.19

6"

PVC (DIPS)

- D. The drawings shall be of sufficient detail for the Engineer to review for conformity to the contract. All drawings shall include elevations on the same datum point as in the contract plans.
- E. Romtec Utilities will manufacture and deliver the pump station as described below to the job site for the contractor. A representative of Romtec Utilities will be present the day of the
- F. The package pump station supplier is responsible for overseeing all start-up, testing and training procedures.

155.12

6"

PVC (DIPS)